



TÜRKİYE DOPİNG KONTROL MERKEZİ  
Hacettepe Üniversitesi, Eczacılık Fakültesi, 06100 Ankara, TÜRKİYE  
Tel ve Fax : 90 (312) 310 67 76 Fax: 90 (312) 312 2062

TURKISH DOPING CONTROL CENTER  
Hacettepe University, Faculty of Pharmacy, 06100 Ankara, TURKEY  
Tel and Fax : 90 (312) 310 67 76 Fax: 90 (312) 312 2062

13.11.2006

**“WEBER.DRY SS-15”  
Analiz Sonuçları**

ELEMENT	SİMGESİ	BİRİM	SINIR DEĞERİ	NUMUNE (Ortalama)	REAGENT BLANK
Alüminyum	Al	µg/L	15,0	<15,0	<15,0
Arsenik	As	µg/L	2,0	<2,0	<2,0
Kadmiyum	Cd	µg/L	0,5	<0,5	<0,5
Krom	Cr	µg/L	5,0	<5,0	<5,0
Demir	Fe	µg/L	20,0	<20,0	<20,0
Kurşun	Pb	µg/L	5,0	<5,0	<5,0
Nikel	Ni	µg/L	5,0	<5,0	<5,0
Selenyum	Se	µ/L	1,0	<1,0	<1,0
Mangan	Mn	µ/L	5,0	<5,0	<5,0

SONUÇ: “WEBER.DRY SS-15 Malzemesi'nin” BS 6920 standardına göre içme suyu ile teması uygundur.